

Date: 11-27-24

Region: 4C

FAC ID: WV006

FEMS/CSS No.: 2965992

Maximo WO No.: 17377



Asset #:

Priority: 1

Original Work Request:

No Heat Call. Boilers are not providing heat because they are timing out.

Description of Repairs Needed:

Proposal is for labor to troubleshoot and diagnose issues on boiler #1. Found that the combustion blower was locked up and windings were open. Shut the boiler off. Verified that the other three boilers were operating properly.

Labor:

	Labor Hrs	Labor Rate	Total
Tech (1)	7.5	\$ 138.00	\$ 1,035.00
Trip Charge	30	\$ 1.75	\$ 52.50
			\$ -

Material List:

	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -

Equipment List:

	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -

PM WO History:

--

Estimate Summary:

Labor	Material	Equipment
\$1,087.50	\$0.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$1,087.50	\$130.50	\$65.25	\$1,283.25