

Date: 4-11-25

Region: 4C

FEMS/CSS No.: 3113820

FAC ID: WV006

Maximo WO No.: 18763

Asset #:

Priority: 3



Original Work Request:

Unclog kitchen sink and repair water heater on dishwasher. The ceramic hand wash sink in the kitchen of Training Bldg needs unclogged, the water heater before the dishwasher is out of service and needs repaired. During PMs Brian from CMI took the water heater out of service because of a leak.

Description of Repairs Needed:

Proposal is to unclog kitchen drain, replace toilet seat in men's restroom and replace dishwasher water heater that is currently out of service.

Labor:

	Labor Hrs	Labor Rate	Total
Tech (1)	8	\$ 100.00	\$ 800.00
			\$ -
			\$ -

Material List:

	Quantity	Cost	Total
Elongated Toilet Seat (Allpoints 1141289)	1	\$ 62.99	\$ 62.99
Booster Heater (Hatco Model S-17, 16 gal, stainless)	1	\$ 3,641.55	\$ 3,641.55
Freight	1	\$ 245.00	\$ 245.00
Misc (electric whip, connectors, shop supplies...)	1	\$ 150.00	\$ 150.00
			\$ -
			\$ -
			\$ -

Equipment List:

	Quantity	Cost	Total
		\$ -	
		\$ -	
		\$ -	

PM WO History:

--

Estimate Summary:

Labor	Material	Equipment
\$800.00	\$4,099.54	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$4,899.54	\$587.94	\$293.97	\$5,781.46