

Date: 7-2-25

Region: 4C

FAC ID: WV006

FEMS/CSS No.: 3220170

Maximo WO No.: 19528

Asset #:

Priority: 1



Original Work Request:

Fire panel alarm. All the fire panels in the facility are alarming and showing communications failure so far we have received 5395 alrarm emails, there is work being done in the AMSA not sure if it has anything to do with this problem. Please have Brewer come and fix. This is an emergency ticket.

Description of Repairs Needed:

Proposal is to investigate and repair issues causing the alarm panel to activate. Discovered trouble on panel is due to construction work on building.

Labor:

| | Labor Hrs | Labor Rate | Total |
|----------|-----------|------------|-----------|
| Tech (1) | 4 | \$ 135.00 | \$ 540.00 |
| tax | 1 | \$ 32.40 | \$ 32.40 |
| | | | \$ - |

Material List:

| | Quantity | Cost | Total |
|--|----------|------|-------|
| | | \$ - | |
| | | \$ - | |
| | | \$ - | |
| | | \$ - | |
| | | \$ - | |
| | | \$ - | |
| | | \$ - | |

Equipment List:

| | Quantity | Cost | Total |
|--|----------|------|-------|
| | | \$ - | |
| | | \$ - | |
| | | \$ - | |

PM WO History:

| |
|--|
| |
| |

Estimate Summary:

| Labor | Material | Equipment |
|----------|----------|-----------|
| \$572.40 | \$0.00 | \$0.00 |

| Sub Total | G&A 12% | Fee 6% | Total Estimate |
|-----------|---------|---------|----------------|
| \$572.40 | \$68.69 | \$34.34 | \$675.43 |