

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

MOTION SENSORS

SITE AND BLDG#:WV007-01

MECHANIC SIGNATURE: Mike Merchant **DATE:** 7 Jul 19

LOCATION/RM#:

START TIME: 1:00pm **FINISH TIME:** 2:00pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Physical Asset Location
WV007-01	9706	6506					J-1502000-18 50-pc Motion Sensor	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule and coordinate work with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		Completed. See COW
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check for proper functioning.	✓		
2	Inspect visual condition of motion lens.	✓		
3	Check for proper light operation.	✓		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: