

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV007 Date of Visit: 06/11/2024

Contractor Personnel on Site:

1. <u>Austin Roberts</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 98171 WO# 209244

Description of Repairs

Replaced and binded the new temperature sensor for circuit 2. Found Circuit 2 was showing symptoms of low refrigerant. Leaked checked and did not find anything but previous leak repair was preformed. Will turn in quote to charge system.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Austin Roberts Date: 06/13/2024

Signed: Austin Roberts

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Thomas Mcburney Date: 6/13/2024

Signed: 

E-Mail: _____