

Date: 8/3/2023

Region: 4C

FAC ID: WV007

CSS No.: 93049

Maximo WO No.: 12990

Asset #:

Priority: 2



Original Work Request:

Fire panel alarming, showing need to replace CO detectors

Description of Repairs Needed:

Replace 2 CO detectors

Labor:	Labor Hrs	Labor Rate	Total
1 Tech	2	\$ 144.00	\$ 288.00
			\$ -

Material List:	Quantity	Cost	Total
Siemens Smoke CO and Heat Detector (OOHC 941)	2	\$ 155.99	\$ 311.98
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -

Equipment List:	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$288.00	\$311.98	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$599.98	\$72.00	\$36.00	\$707.98