

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: WV009-01

**MECHANIC
SIGNATURE:** 

DATE: 6-11-16

LOCATION/RM #:

START TIME: 8:30

FINISH TIME: 9:30

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV009-01	9363	8089					J-1502000-57 7-pc Overhead Vehicle Exhaust System	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Start and stop fan with local switch	X		
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	X		NA direct drive
3	Inspect, adjust belts and pulleys. Replace belt as needed.	X		NA
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	X		NA
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	X		NA
6	Clean fan as needed.	X		NA
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	X		

8	Repair as needed		X	
---	------------------	--	---	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**



Note: unable to get to vehicle exhaust fan due large trailer blocking ladder from being able to be put up. Tested from ground level for proper operation.