

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OIL WATER SEPARATOR

SITE AND BLDG #: **WV009 -01**







MECHANIC
SIGNATURE: James R Groft Jr

DATE: 09/12/2025

LOCATION/RM #: **WO#20037** **ASSET # 9189**

START TIME: _____

FINISH TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)				
		YES	NO	SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X						
TO BE PERFORMED AT EACH INSPECTION SERVICE								
1	OIL LAYER - If possible, measure the surface oil layer in the oil water separator and record depth.	X						
2	SOLID ACCUMULATION - If possible, measure the solid accumulation in the bottom of the oil water separator and record.	X						
3	Recommend whether oil water separator needs to be cleaned.	X						

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description).

To be performed by: General Maintenance Worker

Additional Notes:

urrence. For any deficiencies found the deficiency.

Cleaning not needed at this time. Cleaned 7/16 & 7/17.