

Over and Above Estimate

Region: 4

Location: WV010

CSS #: 17227

Maximo Work Order No.: 8142

Asset#: NA

Date Issued: 02/26/19

Original Description: ISG Found Boiler 2 INOP

Diagnosis: Investment is labor and materials to replace the hot water pump bearing, shaft coupling and impeller for the upper pump in the Motor Pool at USARC Bridgeport, WV010, CSS# 17227

Non Pre-Priced Estimate:

Quantity	Line Item Number	Description	Labor Hours	Unit	Labor	Materials	Equipment	Total
1		186863LF Bearing Assembly, Thermoflo				\$416.26		\$370.03
1		118473 Coupling, Thermoflo				\$45.76		\$473.40
1		P56550 Impeller, Thermoflo				\$322.50		\$322.50

1		Shipping and Handling				\$97.50		\$97.50
1		Trip Charge				\$35.00		\$35.00

Note: RS Means (Pre-Priced) not used in compiling this estimate.

Note: Subcontractor quote attached.

Estimate Summary:

Labor Hours	Labor Cost	Material Cost	Equipment Cost	Total Cost	CE Factor	Total Estimate
Mechanic- \$115 x 8= \$920.00 Apprentice- \$93 x 8= \$744.00	\$1,664.00	\$917.02		\$2,581.02	102%	\$2,632.64

Please see attached estimate

Note:

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Wv010 Date of Visit: 2/27/2019

Contractor Personnel on Site:

1. Robert L. Gifford 2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO# 156774

Service Calls – Service Call Number and Description

1. CSS# 17227
2. CSS# _____
3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Robert L. Gifford Date: 2/27/2019

Signed: 

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Thomas, John W. Date: 2/27/2019

Signed: 

E-Mail: john.w.thomas11.mil@mail.mil



QUOTE

Client Name: USARC - Bridgeport WV01

Contact: Jennifer Bailie

Date: 02/27/2019

Quote Number: 156815

Location: USARC - Bridgeport WV010

Route 2 Box 77

Clarksburg USARC/OMS

Bridgeport, WV 26330

PO Box 627
540 Leon Sullivan Way
Charleston, WV 25301
Charlie Cook
304-346-0549x1252
304-346-8920 Fax
service@castotech.com

Description	Quantity	Price	Line Total
186863LF Bearing Assembly, Thermoflo	1.00	\$416.26	\$416.26
118473 Coupling, Thermoflo	1.00	\$45.76	\$45.76
P56550 Impeller, Thermoflo	1.00	\$322.50	\$322.50
Shipping & Handling	1.00	\$97.50	\$97.50
Onsite Labor Mechanic	8.00	\$115.00	\$920.00
Onsite Labor Apprentice	8.00	\$93.00	\$744.00
Trip Charge	20.00	\$1.75	\$35.00
Subtotal:			\$2,581.02
Estimated Sales Tax:			\$0.00
Total:			\$2,581.02

Investment is labor and materials to replace the hot water pump bearing, shaft coupling and impeller for the upper pump in the Motor Pool at USARC Bridgeport, WV010, CSS# 17227.

This is a quotation on the goods named and further subject to the standard terms and conditions attached hereto.

Acceptance of quotation

Authorized Representative

Purchase Order #

☐ Warranty Option – For an additional \$129.05, I'd like to extend the labor warranty to 12 months.

EXCLUSIONS:

1. All asbestos testing and removal will be owner's responsibility
2. All roof work

CLARIFICATIONS:

1. The price of a performance/payment bond is not included.
2. The cost of permits and inspections by outside authorities are not included.
3. Work will be performed during normal business hours (**Monday-Friday, 8:00 a.m.-4:30 p.m.**).
4. Our terms are net thirty days.
5. Price held firm for 60 days.
6. Standard Warranty - 1 year parts and 90 days labor.

***Thank you for your
business!***

Charlie Cook

From: Charlie Quick
Sent: Wednesday, February 27, 2019 3:15 PM
To: Charlie Cook
Subject: FW: USARC

Charlie

These are for quote number 156774 from Robert for USARC Bridgeport.

MD# Series 60 B & G Pump S/N# 1979664 1-1/4 AA 4 BF

- 1 Bearing Assy. 186863LF \$346.88 ea. Stock at Tec
- 1 Coupling 118473 \$38.13 ea. Stock at Tec
- 1 Impeller P56550 \$268.75 ea. (3 to 4 weeks)

Vendor/ Thermoflo/Mary

Charlie Quick
Purchasing/Parts Sales
Casto Technical Services, Inc.
1428 Pennsylvania Avenue
Charleston, WV 25302
1-304-346-0549

From: Mary Anzelone <MAnzelone@thermoflo.com>
Sent: Wednesday, February 27, 2019 3:09 PM
To: Charlie Quick <cquick@castotech.com>
Subject: [EXTERNAL] RE: USARC

Thanks, mary

From: Charlie Quick <cquick@castotech.com>
Sent: Wednesday, February 27, 2019 1:27 PM
To: Mary Anzelone <MAnzelone@thermoflo.com>
Subject: USARC

Can you get us a quote for these?

BELL & GOSSETT

PUMP CAP.	SIZE	60	PUMP
MOTOR CAP.	HP	1	GPM
SERIAL NO.	1979664	RPM	FT

CSA ENCL 2

