

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**GREASE TRAP**

**SITE AND BLDG #:** WV014-01

**MECHANIC**

**SIGNATURE:** Mike Merchan

**DATE:** 4/17/19

**LOCATION/RM #:**

**START TIME:**

**FINISH TIME:**

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV014-01	7759	7490					J-1502000-48 1-pc Grease Trap cap 50	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
3	Insure proper grease disposal.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Do not use enzymes, acids, caustics, solvents or emulsifying products when cleaning or maintaining the grease traps.			
2	Remove lid. If the trap is equipped with removable baffles, remove them.			
3	Make sure the flow restrictor on the inflow pipe is present.			
4	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.			
5	Replace lid and baffles.			
6	Return (or fill) water to grease trap			

\* This grease trap is no longer in service and needs to service nor inspection

7	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years.			
---	---	--	--	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Technician **Additional Notes:**