

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: WV014-01

MECHANIC
SIGNATURE:

DATE:

Andy Bird 9/4/13

START TIME: 9:30 Pm **FINISH TIME:** 9:55 Pm

LOCATION/RM #:

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV014-01	10755	7470					J-1502000-45 7-pc Flood Light, Pole Mounted	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<i>C</i>		
2	Schedule and coordinate work with operating personnel.	<i>C</i>	<i>C</i>	
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<i>C</i>		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.	<i>C</i>	<i>C</i>	<i>W/T</i>
2	Inspect visual condition of wiring. Look for evidence of overheating.	<i>C</i>		
3	Check for proper light operation.	<i>C</i>		
4	Test operation of automatic switches/ time clock/ photocells if applicable.		<i>C</i>	<i>W/T</i>
5	Inspect light pole and mounting devices for deficiencies.	<i>C</i>		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	<i>C</i>	<i>C</i>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

