

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR HANDLER

SITE AND BLDG #: **WV014-01****MECHANIC****SIGNATURE:** James R Groft Jr**DATE:** 03/03/2025**LOCATION/RM #:****WO#:** 17733**ASSET #:** 9209**START TIME:****FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO	SPECIAL INSTRUCTIONS		
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Check fan blades and moving parts for cracks and excessive wear.	<input checked="" type="checkbox"/>				
2	Check running motor amperatures on all three phases (record in note column) notate L1, L2, and L3 amp draws.-Inspect contactors		<input checked="" type="checkbox"/>	L1_____	L2_____	L3_____ <u>N/A</u>
3	Tighten all electrical connectors/lugs to proper torque.	<input checked="" type="checkbox"/>				
4	If unit is a multi-zone air handler, then check each individual zone damper and associated controls.		<input checked="" type="checkbox"/>		<u>N/A</u>	
5	Check bearing collar set screws on fan shaft to make sure they are tight.	<input checked="" type="checkbox"/>				
6	Replace filters quarterly, replace as necessary. Check belt, repair or replace as necessary.	<input checked="" type="checkbox"/>				
7	Check damper actuators and linkage for proper operation. Adjust linkage on dampers if out of alignment.	<input checked="" type="checkbox"/>				
8	Lubricate mechanical bearings and connections sparingly.	<input checked="" type="checkbox"/>				
9	Clean coils by brushing, blowing, vacuuming	<input checked="" type="checkbox"/>				
10	Check coils for leaking, tightness of fittings.	<input checked="" type="checkbox"/>				
11	Use fin comb to straighten coil fins.	<input checked="" type="checkbox"/>				
12	Report any equipment rust or condensate pan rust -IF found open CM	<input checked="" type="checkbox"/>				
13	Flush and clean condensate pans and drains, Hose down coils and drain pans and wash with an appropriate EPA approved solution approved solution. Treat condensate pans with an EPA approved biocide.		<input checked="" type="checkbox"/>		<u>N/A</u>	
14	Check belts for wear and cracks, adjust tension or alignment. Replace belts when necessary. Multi-belt drives shall only be replaced with matched sets.	<input checked="" type="checkbox"/>				
15	Check rigid couplings for alignment on direct drives, and for tightness of assembly. Check flexible couplings for alignment and wear.		<input checked="" type="checkbox"/>		<u>N/A</u>	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
16	Check and test freezestat for proper operation	<input checked="" type="checkbox"/>		
17	Vacuum interior of unit.	<input checked="" type="checkbox"/>		
18	Check filter doors and access doors for proper gasketing and air leaks. Correct as necessary.	<input checked="" type="checkbox"/>		
19	Lubricate fan shaft bearings while unit is running. Add grease slowly until slight bleeding is noted from the seals. Do not over lubricate. Remove old or excess lubricant.	<input checked="" type="checkbox"/>		
20	Clean up work area.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: