

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**AIR CURTAIN**

**SITE AND BLDG #:** WV016-01

**MECHANIC  
SIGNATURE:**

**DATE:** 6-4-15

**LOCATION/RM #:**

**START TIME:** 10:30

**FINISH TIME:** 11:00

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV016-01	8799	3032	PM-SA-6670		42CHS	98039PB42CHS- L	J-1502000-04 1-pc Air Curtain	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Disconnect the power to the unit.	X		
2	Remove the intake grille by removing all screws around the edges.	X		
3	Vacuum and wash (if necessary) to remove the buildup of dirt and debris.	X		
4	If necessary, lubricate the motors.	X		
5	Reinstall the cover and intake grille.	X		
6	Verify proper operation of unit. Make and/or recommend any needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

