

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
SECURITY SYSTEM

MECHANIC
 SIGNATURE: *Mike Mecham*

SITE AND BLDG #: WV020-01

LOCATION/RM #:

DATE: 12 Aug 19
 START TIME: 1:00 PM FINISH TIME: 2:08 PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV020-01	9713	6431					J-1502000-18 1-pc Security Panel	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>		
2	Always follow lock out/tag out procedures . De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Test the control panels for communications to the monitoring center, sirens, tampers, cameras, and strobe lights.	<input checked="" type="checkbox"/>		
2	Inspect and test the operation of all detection devices	<input checked="" type="checkbox"/>		
3	Check power supplies	<input checked="" type="checkbox"/>		
4	Verify that no compromise to devices has occurred (compromise of devices could be from building alterations, partitions, furniture or other obstacles)	<input checked="" type="checkbox"/>		
5	Test the batteries on remotes and wireless sensors inspection of all visible wiring and conduits	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**