

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST


### AIR CURTAIN

SITE AND BLDG #: WV020-01

LOCATION/RM #: WO# 14213 ASSET # 3031

MECHANIC SIGNATURE: *Rubén A. Bork* DATE: Nov 6, 2023

START TIME: \_\_\_\_\_ FINISH TIME: \_\_\_\_\_

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO		
SPECIAL INSTRUCTIONS					
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Disconnect the power to the unit.	●			
2	Remove the intake grille by removing all screws around the edges.	●			
3	Vacuum and wash (if necessary) to remove the buildup of dirt and debris.	●			
4	If necessary, lubricate the motors.	●			
5	Reinstall the cover and intake grille.	●			
6	Verify proper operation of unit. Make and/or recommend any needed repairs.	●			



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**