


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: WV020-01MECHANIC
SIGNATURE:DATE: Feb 12, 2024LOCATION/RM #: WO# 14816

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO		
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check, clean, and/or replace filters as required.	●			
2	Initial and Date Filter (if disposable)	●			
3	Initial and Date Yellow Maintenance Tag (if applicable)	●			
ASSET #	SIZE	QTY			
3160					
3167	20x25x4	4			
3168	16x25x4	2			
3171					
3173					
3178					
3179					
3198					
3199					
NOTE : Any AHU with outside air -Filter gets replaced Quarterly					
All other filters get replaced annually But inspected Quarterly					

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: