





PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DDC CONTROLLER

SITE AND BLDG #: WV020-01 5255 MECHANIC SIGNATURE: R. Baulu DATE: Mar 11, 2024
 LOCATION/RM #: WO# 15174 ASSET # 5270 5276 START TIME: FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO	SPECIAL INSTRUCTIONS		
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●				
TO BE PERFORMED AT EACH LOCATION						
1	Obtain username and password for login. If not available, contact appropriate company manager to obtain access.	●				
2	Login into system, check for any alarms currently on system. Make necessary repairs to correct alarms back to normal state.	●				
3	Check physical condition of the device. Shut off power to the unit. Vacuum any remaining dust. Turn power back on to the unit.	●				
4	Check all fuses for evidence of heating or weakening.	●				
5	Check system for alarms	●				
6	Check all plug connections in the panel to ensure the plugs are fully seated.	●				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, problem description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: