

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR CURTAIN

SITE AND BLDG #: **WV020-01**

**MECHANIC
SIGNATURE:** *James R Groft Jr*

DATE: **5/21/2025**

LOCATION/RM #: **WO# 18660** **ASSET # 3031**

START TIME:**FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		•	NO ACCESS AT THIS TIME
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Disconnect the power to the unit.		•	
2	Remove the intake grille by removing all screws around the edges.		•	
3	Vacuum and wash (if necessary) to remove the buildup of dirt and debris.		•	
4	If necessary, lubricate the motors.		•	
5	Reinstall the cover and intake grille.		•	
6	Verify proper operation of unit. Make and/or recommend any needed repairs.		•	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: