

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

HOT WATER PUMP

SITE AND BLDG #: WV020-02

MECHANIC
SIGNATURE: 

DATE: 6-13-15

LOCATION/RM #:

START TIME:

FINISH TIME:

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV020-02	9249	5001					J-1502000-12 2-pc Hot Water Pump	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X		
2	Schedule outage with operating personnel.	X		
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
4	If the material removed from the pump is hazardous, contact the Regional S&EM office for disposal instructions.	X		
5	If strainer cleaning requires removal of pump unit which should be considered a repair and not general maintenance.	X		
6	Excessive sediment and debris, not removed by flushing the pit should be handled on a project basis, and not considered under this standard.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Remove cover plates and flush pit.	X		
2	Inspect check valve.	X		
3	Inspect interior of pit for cracks.	X		

4	Inspect cover plate gaskets and replace if necessary.	X		
5	Insure the unit is operating properly, report any deficiencies	X		
6	Clean up work area and remove all debris.	2		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**