

## REVIEWED

By Mike Merchan at 10:40 am, Apr 05, 2019

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**LIGHTING, OUTSIDE**

SITE AND BLDG #: WV020-02

LOCATION/RM #: REAR LOT

MECHANIC

SIGNATURE: *Geo. E. G.*

DATE: 04 APR 19

START TIME: 10:00 A

FINISH TIME: 11:00 A

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV020-02	8353	7436					J-1502000-45 2-pc Double Light, Pole Mounted Aluminum Metal Halide Time Clock	LOT

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule and coordinate work with operating personnel.	✓		
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.	✓		
2	Inspect visual condition of wiring. Look for evidence of overheating.	✓		
3	Check for proper light operation.	✓		(3) OF 4 LIGHTS OUT
4	Test operation of automatic switches/ time clock/ photocells if applicable.	✓		TIME CLOCK WORKING PROPERLY
5	Inspect light pole and mounting devices for deficiencies.	✓		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓		(3) POLE LIGHTS OUT NEED CM

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**



(2) POLE LIGHTS OUT ON SOUTH SIDE, (1) ON NORTH SIDE OUT  
NEEDS CM TICKET CREATED