

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**EXHAUST FANS**

**SITE AND BLDG #:** WV020-02

**LOCATION/RM #:** WO# 14479 ASSET # 3883



**MECHANIC  
SIGNATURE:**

*Ronald A. Banks*

**DATE:** Dec 14, 2023

**START TIME:**

**FINISH TIME:**

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS</b> (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		<b>YES</b>	<b>NO</b>	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Clean unit, especially fan blades.	●		
2	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multiple belts should be replaced with matched sets.	●		
3	Perform required lubrication and remove old or excess lubricant.	●		
4	Clean motor with vacuum or low pressure dry air (less than 40 psig). Check for obstructions in motor cooling and air flow.	●		
5	Check structural members, vibration eliminators, and flexible connections. Check fan housing to ensure there is no damage and the housing is tight.	●		
6	Start unit and check for vibration and noise.	●		
7	Remove all trash and debris.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**