

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR DRYER, REFRIGERATED

SITE AND BLDG #: WV020-02LOCATION/RM #: WO# 15542 ASSET # 3033MECHANIC
SIGNATURE:DATE: May 7, 2024

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Lubricate valves and replace packing, as needed.	●		
2	Check dryer operating cycle.	●		
3	Inspect and clean heat exchanger, as needed.	●		
4	Check automatic blow down devices.	●		
5	Inspect and replace or reinstall inlet filters.	●		
6	Check for proper operation and ensure no refrigerant leaks.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: