

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, HOT WATER

SITE AND BLDG #: WV020-02 **4399**
LOCATION/RM #: WO# 16033 **4532** ASSET #











**MECHANIC
SIGNATURE:**

RBanker

DATE: Jul 8, 2024

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel.	●		  
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		  
TO BE PERFORMED AT EACH INSPECTION				
1	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	●		  
2	Clean the coils	●		  
3	Comb the fins as needed.	●		  
4	Clean all fans and motors.	●		  
5	Check operation of controls and safeties.	●		  
6	Lubricate as required.	●		  
7	Check all motors, belts, pulleys, shafts, etc. for alignment.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: