

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**CHEMICAL BYPASS/POT FEEDER**


**SITE AND BLDG #:** WV020-02

**MECHANIC SIGNATURE:**  **DATE:** Sep 9, 2024

**LOCATION/RM #:** WO# 16520 **ASSET #** 4838

**START TIME:** \_\_\_\_\_ **FINISH TIME:** \_\_\_\_\_

| CHECK POINT                                | CHECKPOINT DESCRIPTION                                                                                                                                      | TASK COMPLETE |    | NOTES/ ACTIONS<br>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)             |  |
|--------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|----|-------------------------------------------------------------------------------------|--|
|                                            |                                                                                                                                                             | YES           | NO |                                                                                     |  |
| SPECIAL INSTRUCTIONS                       |                                                                                                                                                             |               |    |                                                                                     |  |
| 1                                          | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | ●             |    |  |  |
| TO BE PERFORMED AT EACH INSPECTION SERVICE |                                                                                                                                                             |               |    |                                                                                     |  |
| 1                                          | Check physical condition of feeder. Clean and/or repair as needed.                                                                                          | ●             |    |                                                                                     |  |
| 2                                          | Check valves for proper operation. Ensure no leaks are present and repair as needed.                                                                        | ●             |    |                                                                                     |  |



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**