


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR DRYER, REFRIGERATED

MECHANIC
SIGNATURE:



DATE: 11/12/2024

SITE AND BLDG #: WV020-02

LOCATION/RM #: WO# 17018 ASSET # 3033

START TIME:

FINISH TIME:

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|--|---|---------------|----|---|
| | | YES | NO | |
| SPECIAL INSTRUCTIONS | | | | |
| 1 | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | ● | | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Lubricate valves and replace packing, as needed. | ● | | |
| 2 | Check dryer operating cycle. | ● | | |
| 3 | Inspect and clean heat exchanger, as needed. | ● | | |
| 4 | Check automatic blow down devices. | ● | | |
| 5 | Inspect and replace or reinstall inlet filters. | ● | | |
| 6 | Check for proper operation and ensure no refrigerent leaks. | ● | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

Additional Notes: