


Argent Inspections

Form AI-08

Boiler Inspection Certificate


| | | | | |
|--|-----------------------------|--|--|----------------------------|
| Expiration Date 8/3/2024 | Inspection Date 8/3/2023 | Next Watersides/Firesides 2026/2024 | Next Strength Test | National Board # 197847 |
| Customer 99th RSC R4C WV020 USARC Jane Lew | | Manufacturer Laars | | Year Built 2008 |
| Building # Mechanical Room | | Serial # H-08-197847 | Property # 2 | Jurisdiction # |
| Pressure Allowed 160 psi | Capacity 250000 btuh | Safety Valves 1 | Programmer Mfr UT Controls | Burner Mfr Laars |
| Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness | | | Fuel Type(s) Certified to Use <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil | |
| Commission # 13373 | Inspector: Dale Brooks | Signature  | | |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER


Argent Inspections

Form AI-08

Boiler Inspection Certificate

| | | | | |
|---|-----------------------------|--|---|----------------------------|
| Expiration Date 8/3/2024 | Inspection Date 8/3/2023 | Next Watersides/Firesides 2024/2024 | Next Strength Test | National Board # 197846 |
| Customer 99th RSC R4C WV020 USARC Jane Lew | | Manufacturer Laars | | Year Built 2008 |
| Building # Mechanical Room | | Serial # H-08-197846 | Property # 4 | Jurisdiction # |
| Pressure Allowed 160 psi | Capacity 250000 btuh | Safety Valves 1 | Programmer Mfr UT Controls | Burner Mfr Laars |
| Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness | | | Fuel Type(s) Certified to Use <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input checked="" type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil | |
| Commission # 13373 | Inspector: Dale Brooks | Signature  | | |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER

| Argent Inspections | | | | |
|---|------------------------------|--|-----------------------------|----------------------|
| Form AI-09 | | Pressure Vessel Inspection Certificate | | |
| Expiration Date 8/3/2026 | Inspection Date 8/3/2023 | National Board # 529294 | Pressure Allowed 200 psi | Capacity 16 cu.ft |
| Customer 99 RSC R4A WV020 USARC Jane Lew | | Manufacturer Manchester | | Year Built 1997 |
| Location/Building # Mechanical Room | | Serial # NB 529294 | Property # | |
| Inspection Type(s) Performed | | Vessel Type | | |
| <input checked="" type="checkbox"/> External <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Operational <input checked="" type="checkbox"/> Pressure | | <input checked="" type="checkbox"/> Air Receiver <input type="checkbox"/> Autoclave <input type="checkbox"/> Heat Exchanger <input type="checkbox"/> Hot Water <input type="checkbox"/> Nitrogen <input type="checkbox"/> Oxygen <input type="checkbox"/> Other | | |
| Commission # 13373 | Inspector: Dale A. Brooks | | | |
| Signature  | | | | |

POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED Vessel