





TRANE
CLARKSVILLE, TN
ASSEMBLED IN MEXICO

Odyssey™

MODEL NO. TTA240H300AA

SERIAL NO. 16205UF0TA
SUITABLE FOR OUTDOOR USE

MFG. DATE 5/2016

CPR. MOT. (2) 3 1/2 FLA

208-230 V	3PH	60HZ	267 LRA
208-230 V	1PH	60HZ	1 HP

O.D. MOT. (2) 5 FLA
TEST PSI HIGH 449 LOW 239

REFRIGERANT R410A "A" CPR
FIELD CHARGE "B" CPR

LBS OZ
LBS OZ

FOR CHARGING DATA SEE UNIT SERVICE FACTS

MIN CKT AMPS 98

DATA FOR USA INSTALLATION
HACR TYPE CKT. BREAKER 125 AMPS

MAX. FUSE (AMPS) 125

SHORT - CIRCUIT CURRENT RATING:
5 KA RMS SYMMETRICAL

REFERENCE UNIT/MOTOR VOLTAGE

DATA FOR CANADIAN INSTALLATION
CKT. BREAKER 125 AMPS

MAX. FUSE (AMPS) 125

SEE "ELECTRIC HEATER INSTALLED"
NAMEPLATE FOR HEATER RATING

EQUIPMENT COMPLIES WITH THE
REQUIREMENTS OF ASHRAE STANDARD 90.1
43674782A REV - E

AHRI CERTIFIED
www.ahri.org

UL US
LISTED
19V/F

4367 - 1624 - 1300 REV H

R-4
ONLY

RECOMMENDED COIL CLEANING PROCEDURE
NETTOYAGE DES SERPENTINS
PROCEDIMIENTO DE LIMPIEZA RECOMENDADA