

# Argent Inspections

## Form AI-03


## Boiler Inspection Report

Inspection Date 10/1/2024	Certificate Issued Yes	Expiration Date 10/1/2025	Prepared for Inspection Yes	Next Watersides/Firesides 2027/2025	Next Strength Test	
Inspection Type(s) Performed <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness						
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room			
Address 7605 US Rt 19 North			Boiler Location Address			
City Jane Lew		State WV	Zip 26378-7999	City		
State WV		Zip 26378-7999	City		State WV	Zip 26378-7999
National Board # 286805	Jurisdiction #	Property # 1	Boiler Use Heating Hot Water Loop		Fuel Type Nat. Gas	
Manufacturer Lochinvar		Model # KHB285N		Serial # 2226 130077997		Year Built 2021
Capacity 285,000 btuh	Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar		Burner Manufacturer Lochinvar	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO				Flue Gas Temperature Degrees F	
	Valve Manufacturer Cash Acme	Size .75 in.	Set Pressure 30 psi	Capacity 510,000 btuh	Lift Pressure	Reseat Pressure
Valve 1						
Valve 2						
Valve 3:						
Valve 4:						
Safety Devices Tested Flame Rod, Low Water Lockout, Blocked Flue Switch, Blocked Intake Switch, Operating Temperature Control, Automatic Reset High Temperature Limit, Manual Reset High Temperature Limit, and 2 Remote Emergency Stop.						
Reason(s) for Declining Certification						
Comments This new installation replaced boiler NB 197843. This boiler was inspected per UFC 3-430-07. The BTU input of this boiler is below the minimum for which UFC 3-430-07 requires mandatory inspections. In the interest of safety, the boiler was inspected at the request of the activity as allowed by Para. 1-5 of UFC 3-430-07. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. All safety devices tested functioned properly during the inspection process. Safety valve spindle not vertical. Discharge of safety valve manifolded with #3 boiler. Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.						
Inspector Commission 13373	Inspector Dale Brooks	Signature <i>Dale Brooks</i>				
Attachments No	Technical Manager Jerry Kuykendall	Signature <i>Jerry Kuykendall</i>				

# Argent Inspections

## Form AI-03

## Boiler Inspection Report

Inspection Date 10/1/2024	Certificate Issued Yes	Expiration Date 10/1/2025	Prepared for Inspection Yes	Next Watersides/Firesides 2027/2025	Next Strength Test
Inspection Type(s) Performed <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness					
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room		
Address 7605 US Rt 19 North			Boiler Location Address		
City Jane Lew		State WV	Zip 26378-7999	City	State Zip
National Board # 261918	Jurisdiction #	Property # 2	Boiler Use Heating Hot Water Loop	Fuel Type Nat. Gas	
Manufacturer Lochinvar		Model # KHB285N		Serial # 2237 130933470	Year Built 2021
Capacity 285, 000 btuh	Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar	Burner Manufacturer Lochinvar	
Number of Safety Valves 1	Combustion Efficiency % CO2      ppm CO      % Excess O2				Flue Gas Temperature Degrees F
	Valve Manufacturer	Size	Set Pressure	Capacity	Lift Pressure
Valve 1	Cash Acme	.75 in.	30 psi	510,000 btuh	
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Low Water Lockout, Blocked Flue Switch, Blocked Intake Switch, Operating Temperature Control, Automatic Reset High Temperature Limit, Manual Reset High Temperature Limit, and 2 Remote Emergency Stop.					
Reason(s) for Declining Certification					
Comments This new installation replaced boiler NB 197847. This boiler was inspected per UFC 3-430-07. The BTU input of this boiler is below the minimum for which UFC 3-430-07 requires mandatory inspections. In the interest of safety, the boiler was inspected at the request of the activity as allowed by Para. 1-5 of UFC 3-430-07. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. All safety devices tested functioned properly during the inspection process. Safety valve spindle not vertical. Discharge of safety valve manifolded with #4 boiler. Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments	Technical Manager	Signature			
No Pages	Jerry Kuykendall				

# Argent Inspections

Form AI-03



## Boiler Inspection Report

Inspection Date 10/1/2024	Certificate Issued Yes	Expiration Date 10/1/2025	Prepared for Inspection Yes	Next Watersides/Firesides 2026/2025	Next Strength Test
Inspection Type(s) Performed <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness					
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room		
Address 7605 US Rt 19 North			Boiler Location Address		
City Jane Lew		State WV	Zip 26378-7999	City	State Zip
National Board # 261917	Jurisdiction #	Property # 3	Boiler Use Heating Hot Water Loop	Fuel Type Nat. Gas	
Manufacturer Lochinvar		Model # KHB285N		Serial # 2237 130933471	Year Built 2021
Capacity 285,000 btuh		Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar	Burner Manufacturer Lochinvar
Number of Safety Valves 1		Combustion Efficiency % CO2      ppm CO      % Excess O2			Flue Gas Temperature Degrees F
	Valve Manufacturer Cash Acme	Size .75 in.	Set Pressure 30 psi	Capacity 510,000 btuh	Lift Pressure
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Low Water Lockout, Blocked Flue Switch, Blocked Intake Switch, Operating Temperature Control, Automatic Reset High Temperature Limit, Manual Reset High Temperature Limit, and 2 Remote Emergency Stop.					
Reason(s) for Declining Certification					
Comments This new installation replaced boiler NB 197840. This boiler was inspected per UFC 3-430-07. The BTU input of this boiler is below the minimum for which UFC 3-430-07 requires mandatory inspections. In the interest of safety, the boiler was inspected at the request of the activity as allowed by Para. 1-5 of UFC 3-430-07. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. All safety devices tested functioned properly during the inspection process. Safety valve spindle not vertical. Discharge of safety valve manifolded with #1 boiler. Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature <i>Dale O. Brooks</i>			
Attachments No	Technical Manager Pages	Signature <i>Jerry Kuykendall</i>			

# Argent Inspections

Form AI-03

## Boiler Inspection Report

Inspection Date 10/1/2024	Certificate Issued Yes	Expiration Date 10/1/2025	Prepared for Inspection Yes	Next Watersides/Firesides 2027/2025	Next Strength Test
Inspection Type(s) Performed <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness					
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room		
Address 7605 US Rt 19 North			Boiler Location Address		
City Jane Lew		State WV	Zip 26378-7999	City	State Zip
National Board # 280593	Jurisdiction #	Property # 4	Boiler Use Heating Hot Water Loop	Fuel Type Nat. Gas	
Manufacturer Lochinvar		Model # KHB285N		Serial # 2226 1300077986	Year Built 2021
Capacity 285,000 btuh		Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar	Burner Manufacturer Lochinvar
Number of Safety Valves 1		Combustion Efficiency % CO2      ppm CO      % Excess O2      Flue Gas Temperature Degrees F			
	Valve Manufacturer Cash Acme	Size .75 in.	Set Pressure 30 psi	Capacity 510,000 btuh	Lift Pressure
Valve 1					
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Low Water Lockout, Blocked Flue Switch, Blocked Intake Switch, Operating Temperature Control, Automatic Reset High Temperature Limit, Manual Reset High Temperature Limit, and 2 Remote Emergency Stop.					
Reason(s) for Declining Certification					
Comments This new installation replaced boiler NB 197846. This boiler was inspected per UFC 3-430-07. The BTU input of this boiler is below the minimum for which UFC 3-430-07 requires mandatory inspections. In the interest of safety, the boiler was inspected at the request of the activity as allowed by Para. 1-5 of UFC 3-430-07. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. All safety devices tested functioned properly during the inspection process. Safety valve spindle not vertical. Discharge of safety valve manifolded with #2 boiler. Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments	Technical Manager	Signature			
No Pages	Jerry Kuykendall				

# Argent Inspections

## Form AI-03

## Boiler Inspection Report

Inspection Date 10/1/2024	Certificate Issued Yes	Expiration Date 10/1/2025	Prepared for Inspection Yes	Next Watersides/Firesides 2025/2025	Next Strength Test
Inspection Type(s) Performed <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness					
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room		
Address 7605 US Rt 19 North			Boiler Location Address		
City Jane Lew		State WV	Zip 26378-7999	City	State Zip
National Board # 72859	Jurisdiction #	Property # 1	Boiler Use Heating Hot Water Loop	Fuel Type Nat. Gas	
Manufacturer Lochinvar		Model # RBN090PM		Serial # C873701	Year Built 1997
Capacity 90,000 btuh	Design Pressure 160 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar	Burner Manufacturer Lochinvar	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2				Flue Gas Temperature Degrees F
	Valve Manufacturer Watts	Size .75 in.	Set Pressure 30 psi	Capacity 650,000 btuh	Lift Pressure
Valve 1					
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Operating Temperature Control, High Temperature Limit, Remote Emergency Stop.					
Reason(s) for Declining Certification					
Comments This boiler was inspected per UFC 3-430-07. The BTU input of this boiler is below the minimum for which UFC 3-430-07 requires mandatory inspections. In the interest of safety, the boiler was inspected at the request of the activity as allowed by Para. 1-5 of UFC 3-430-07. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. All safety devices tested functioned properly during the inspection process.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments	Technical Manager	Signature			
No Pages	Jerry Kuykendall				

## Argent Inspections

**Form AI-08**

### Boiler Inspection Certificate

Expiration Date <b>10/1/2025</b>	Inspection Date <b>10/1/2024</b>	Next Watersides/Firesides <b>2027/2025</b>	Next Strength Test	National Board # <b>286805</b>
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar	Year Built <b>2021</b>	
Building # Mechanical Room		Serial # 2226 130077997	Property # <b>1</b>	Jurisdiction #
Pressure Allowed 80 psi	Capacity 285,000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar
Inspection Type(s) Performed  <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness			Fuel Type(s) Certified to Use  <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil	
Commission # <b>13373</b>	Inspector: <b>Dale Brooks</b>	Signature		

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*

# Argent Inspections

**Form AI-08**

## Boiler Inspection Certificate

Expiration Date <b>10/1/2025</b>	Inspection Date 10/1/2024	Next Watersides/Firesides 2027/2025	Next Strength Test	National Board # 261918
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar	Year Built 2021	
Building # Mechanical Room		Serial # 2237 130933470	Property # 2	Jurisdiction #
Pressure Allowed 80 psi	Capacity 285, 000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar
Inspection Type(s) Performed			Fuel Type(s) Certified to Use	
<input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness			<input type="checkbox"/> Coal <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Heavy Fuel Oil <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Wood	
Commission # 13373	Inspector: Dale Brooks	Signature 		

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*

## Argent Inspections

**Form AI-08**

### Boiler Inspection Certificate

Expiration Date <b>10/1/2025</b>	Inspection Date <b>10/1/2024</b>	Next Watersides/Firesides <b>2026/2025</b>		Next Strength Test	National Board # <b>261917</b>
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar			Year Built <b>2021</b>
Building # Mechanical Room		Serial # 2237 130933471		Property # <b>3</b>	Jurisdiction #
Pressure Allowed 80 psi	Capacity 285,000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar	
Inspection Type(s) Performed  <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness			Fuel Type(s) Certified to Use  <input type="checkbox"/> Coal <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Heavy Fuel Oil <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Wood		
Commission # <b>13373</b>	Inspector: <b>Dale Brooks</b>	Signature 			

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*

## Argent Inspections

### Form AI-08

### Boiler Inspection Certificate


Expiration Date <b>10/1/2025</b>	Inspection Date 10/1/2024	Next Watersides/Firesides 2027/2025	Next Strength Test	National Board # 280593
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar	Year Built 2021	
Building # Mechanical Room		Serial # 2226 1300077986	Property # 4	Jurisdiction #
Pressure Allowed 80 psi	Capacity 285,000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar
Inspection Type(s) Performed  <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness			Fuel Type(s) Certified to Use  <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil	
Commission # 13373	Inspector: Dale Brooks	Signature <i>Dale B. Brooks</i>		

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*

## Argent Inspections

### Form AI-08

### Boiler Inspection Certificate

Expiration Date <b>10/1/2025</b>	Inspection Date 10/1/2024	Next Watersides/Firesides 2025/2025		Next Strength Test	National Board # 72859
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Manufacturer Lochinvar	Year Built 1997	
Building # Mechanical Room		Serial # C873701		Property # 1	Jurisdiction #
Pressure Allowed 160 psi	Capacity 90,000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar	
Inspection Type(s) Performed			Fuel Type(s) Certified to Use		
<input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness			<input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil		
Commission # 13373	Inspector: Dale Brooks	Signature 			

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*