

# Argent Inspections

## Form AI-03



## Boiler Inspection Report

Inspection Date 11/19/2025	Certificate Issued Yes	Expiration Date 11/19/2026	Prepared for Inspection Yes	Next Watersides/Firesides 2027/2026	Next Strength Test	
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness						
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room			
Address 7605 US Rt 19 North			Boiler Location Address			
City Jane Lew		State WV	Zip 26378-7999	City		
State WV		Zip 26378-7999	City		State WV	
National Board # 286805	Jurisdiction #	Property # 1	Boiler Use Heating Hot Water Loop	Fuel Type Nat. Gas		
Manufacturer Lochinvar		Model # KHB285N		Serial # 2226 130077997	Year Built 2021	
Capacity 285,000 btuh		Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar	Burner Manufacturer Lochinvar	
Number of Safety Valves 1		Combustion Efficiency % CO2 ppm CO % Excess O2 Flue Gas Temperature Degrees F				
	Valve Manufacturer Cash Acme	Size .75 in.	Set Pressure 30 psi	Capacity 510,000 btuh	Lift Pressure	Reseat Pressure
Valve 1						
Valve 2						
Valve 3:						
Valve 4:						
Safety Devices Tested Flame Rod, Low Water Lockout, Blocked Flue Switch, Blocked Intake Switch, Operating Temperature Control, Automatic Reset High Temperature Limit, Manual Reset High Temperature Limit, and 2 Remote Emergency Stop. Safety valve was lifted by hand per NBIC Part 2 para 2.5.7.1 d. It lifted freely and reseated with no leakage.						
Reason(s) for Declining Certification						
Comments This boiler was inspected using National Board inspection Code and ASME-CSD-1 as guides. The BTU rating of the boiler is less than the minimum for which all the requirements of ASME-CSD-1 apply. In the interest of safety, the boiler was inspected at the request of the activity. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. Light debris observed on firesides. There was no evidence of leakage with 10 psi on the watersides. All safety devices tested functioned properly during the inspection process. Safety valve spindle not vertical. Per NBIC Part Sec 3.9.1.1.1 the safety valve spindle must be installed in the vertical position. Discharge of safety valve manifolded with #3 boiler, cross sectional area of the manifold must be equal to the combined areas of all safety valve discharging into the manifold,(NBIC Part1 Sec 3.9.5). Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.						
Inspector Commission 13373	Inspector Dale Brooks	Signature 				
Attachments Yes 2 Pages	Technical Manager Jerry Kuykendall	Signature 				

# Argent Inspections

## Form AI-03

## Boiler Inspection Report

Inspection Date 11/19/2025	Certificate Issued Yes	Expiration Date 11/19/2026	Prepared for Inspection Yes	Next Watersides/Firesides 2027/2026	Next Strength Test
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness					
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room		
Address 7605 US Rt 19 North			Boiler Location Address		
City Jane Lew		State WV	Zip 26378-7999	City	
National Board # 261918	Jurisdiction #	Property # 2	Boiler Use Heating Hot Water Loop		Fuel Type Nat. Gas
Manufacturer Lochinvar		Model # KHB285N		Serial # 2237 130933470	Year Built 2021
Capacity 285,000 btuh	Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar		Burner Manufacturer Lochinvar
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2				Flue Gas Temperature Degrees F
Valve 1	Valve Manufacturer Cash Acme	Size .75 in.	Set Pressure 30 psi	Capacity 510,000 btuh	Lift Pressure
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Low Water Lockout, Blocked Flue Switch, Blocked Intake Switch, Operating Temperature Control, Automatic Reset High Temperature Limit, Manual Reset High Temperature Limit, and 2 Remote Emergency Stop. Safety valve was lifted by hand per NBIC Part 2 para 2.5.7.1 d. It lifted freely and reseated with no leakage.					
Reason(s) for Declining Certification					
Comments This boiler was inspected using National Board inspection Code and ASME-CSD-1 as guides. The BTU rating of the boiler is less than the minimum for which all the requirements of ASME-CSD-1 apply. In the interest of safety, the boiler was inspected at the request of the activity. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. Light debris observed on firesides. There was no evidence of leakage with 10 psi on the watersides. All safety devices tested functioned properly during the inspection process. Safety valve spindle not vertical. Per NBIC Part Sec 3.9.1.1.1 the safety valve spindle must be installed in the vertical position. Discharge of safety valve manifolded with #3 boiler, cross sectional area of the manifold must be equal to the combined areas of all safety valve discharging into the manifold, (NBIC Part 1 Sec 3.9.5). Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments Yes 2 Pages	Technical Manager Jerry Kuykendall	Signature 			

# Argent Inspections

## Form AI-03



## Boiler Inspection Report

Inspection Date 11/19/2026	Certificate Issued Yes	Expiration Date 11/19/2026	Prepared for Inspection Yes	Next Watersides/Firesides 2026/2026	Next Strength Test
Inspection Type(s) Performed					
<input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness					
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room		
Address 7605 US Rt 19 North			Boiler Location Address		
City Jane Lew		State WV	Zip 26378-7999	City	
State WV		Zip 26378-7999	City		State WV
National Board # 261917	Jurisdiction #	Property # 3	Boiler Use Heating Hot Water Loop		Fuel Type Nat. Gas
Manufacturer Lochinvar		Model # KHB285N		Serial # 2237 130933471	Year Built 2021
Capacity 285,000 btuh	Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar		Burner Manufacturer Lochinvar
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2				Flue Gas Temperature Degrees F
Valve 1	Valve Manufacturer Cash Acme	Size .75 in.	Set Pressure 30 psi	Capacity 510,000 btuh	Lift Pressure
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Low Water Lockout, Blocked Flue Switch, Blocked Intake Switch, Operating Temperature Control, Automatic Reset High Temperature Limit, Manual Reset High Temperature Limit, and 2 Remote Emergency Stop. Safety valve was lifted by hand per NBIC Part 2 para 2.5.7.1 d. It lifted freely and reseated with no leakage.					
Reason(s) for Declining Certification					
Comments This boiler was inspected using National Board inspection Code and ASME-CSD-1 as guides. The BTU rating of the boiler is less than the minimum for which all the requirements of ASME-CSD-1 apply. In the interest of safety, the boiler was inspected at the request of the activity. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. It was unsafe to get on a ladder to inspect fireside. All safety devices tested functioned properly during the inspection process. Safety valve spindle not vertical. Per NBIC Part 1 Sec 3.9.1.1.1 the safety valve spindle must be installed in the vertical position. Discharge of safety valve manifolded with #3 boiler, cross sectional area of the manifold must be equal to the combined areas of all safety valve discharging into the manifold,(NBIC Part1 Sec 3.9.5). Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature <i>Dale O. Brooks</i>			
Attachments Yes 2 Pages	Technical Manager Jerry Kuykendall	Signature <i>Jerry Kuykendall</i>			

# Argent Inspections

## Form AI-03


## Boiler Inspection Report

Inspection Date 11/19/2025	Certificate Issued Yes	Expiration Date 11/19/2026	Prepared for Inspection Yes	Next Watersides/Firesides 2027/2026	Next Strength Test
Inspection Type(s) Performed <input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness					
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room		
Address 7605 US Rt 19 North			Boiler Location Address		
City Jane Lew		State WV	Zip 26378-7999	City	State Zip
National Board # 280593	Jurisdiction #	Property # 4	Boiler Use Heating Hot Water Loop	Fuel Type Nat. Gas	
Manufacturer Lochinvar		Model # KHB285N		Serial # 2226 1300077986	Year Built 2021
Capacity 285,000 btuh	Design Pressure 80 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar	Burner Manufacturer Lochinvar	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO			% Excess O2	Flue Gas Temperature Degrees F
	Valve Manufacturer Cash Acme	Size .75 in.	Set Pressure 30 psi	Capacity 510,000 btuh	Lift Pressure
Valve 2					
Valve 3:					
Valve 4:					
Safety Devices Tested Flame Rod, Low Water Lockout, Blocked Flue Switch, Blocked Intake Switch, Operating Temperature Control, Automatic Reset High Temperature Limit, Manual Reset High Temperature Limit, and 2 Remote Emergency Stop. Safety valve was lifted by hand per NBIC Part 2 para 2.5.7.1 d. It lifted freely and reseated with no leakage.					
Reason(s) for Declining Certification					
Comments This boiler was inspected using National Board inspection Code and ASME-CSD-1 as guides. The BTU rating of the boiler is less than the minimum for which all the requirements of ASME-CSD-1 apply. In the interest of safety, the boiler was inspected at the request of the activity. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. It was unsafe to get on a ladder to inspect fireside. All safety devices tested functioned properly during the inspection process. Safety valve spindle not vertical. Per NBIC Part 1 Sec 3.9.1.1.1 the safety valve spindle must be installed in the vertical position. Discharge of safety valve manifolded with #3 boiler, cross sectional area of the manifold must be equal to the combined areas of all safety valve discharging into the manifold,(NBIC Part1 Sec 3.9.5). Discharge of safety valve should be piped back to Glycol supply tank. Carbon Monoxide monitor/alarm present.					
Inspector Commission 13373	Inspector Dale Brooks	Signature 			
Attachments Yes 2 Pages	Technical Manager Jerry Kuykendall	Signature 			

# Argent Inspections

## Form AI-03

## Boiler Inspection Report

Inspection Date 11/19/2025	Certificate Issued Yes	Expiration Date 11/19/2026	Prepared for Inspection Yes	Next Watersides/Firesides 2028/2026	Next Strength Test	
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness						
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew			Boiler Location Name and/or Building Number Mechanical Room			
Address 7605 US Rt 19 North			Boiler Location Address			
City Jane Lew		State WV	Zip 26378-7999	City		
State WV		Zip 26378-7999	City		State WV	Zip 26378-7999
National Board # 72859	Jurisdiction #	Property # 1	Boiler Use Heating Hot Water Loop		Fuel Type Nat. Gas	
Manufacturer Lochinvar		Model # RBN090PM		Serial # C873701		Year Built 1997
Capacity 90,000 btuh	Design Pressure 160 psi	Operating Pressure 12-20 psi	Programmer Manufacturer Lochinvar		Burner Manufacturer Lochinvar	
Number of Safety Valves 1	Combustion Efficiency % CO2 ppm CO % Excess O2				Flue Gas Temperature Degrees F	
	Valve Manufacturer Watts	Size .75 in.	Set Pressure 30 psi	Capacity 650,000 btuh	Lift Pressure Hand	Reseat Pressure Sat.
Valve 1						
Valve 2						
Valve 3:						
Valve 4:						
Safety Devices Tested Flame Rod, Operating Temperature Control, High Temperature Limit, Remote Emergency Stop, and the safety valve was lifted by hand per NBIC Part 2 para. 2.5.7.1 (d). It lifted freely and reseated with no leakage.						
Reason(s) for Declining Certification						
Comments This boiler was inspected using National Board inspection Code and ASME-CSD-1 as guides. The BTU rating of the boiler is less than the minimum for which all the requirements of ASME-CSD-1 apply. In the interest of safety, the boiler was inspected at the request of the activity. The scope of the inspection was to verify the integrity of the vessel and prove that all installed safety controls functioned as designed. Light scale observed on watersides, and light debris on firesides. There was no evidence of leakage with 15 psi on the watersides. All safety devices tested functioned properly during the inspection process.						
Inspector Commission 13373	Inspector Dale Brooks	Signature 				
Attachments No	Technical Manager Pages	Signature 				
Jerry Kuykendall						

## Argent Inspections

**Form AI-08**

### Boiler Inspection Certificate

Expiration Date <b>11/19/2026</b>	Inspection Date 11/19/2025	Next Watersides/Firesides 2027/2026	Next Strength Test	National Board # 286805
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar	Year Built 2021	
Building # Mechanical Room		Serial # 2226 130077997	Property # 1	Jurisdiction #
Pressure Allowed 80 psi	Capacity 285,000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness			Fuel Type(s) Certified to Use <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil	
Commission # 13373	Inspector: Dale Brooks	Signature		

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*

## Argent Inspections

**Form AI-08**

### Boiler Inspection Certificate

Expiration Date <b>11/19/2026</b>	Inspection Date 11/19/2025	Next Watersides/Firesides 2027/2026		Next Strength Test	National Board # 261918
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar			Year Built 2021
Building # Mechanical Room		Serial # 2237 130933470		Property # 2	Jurisdiction #
Pressure Allowed 80 psi	Capacity 285, 000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar	
Inspection Type(s) Performed			Fuel Type(s) Certified to Use		
<input checked="" type="checkbox"/> Internal <input type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness			<input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil		
Commission # 13373	Inspector: Dale Brooks	Signature 			

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*

## Argent Inspections

**Form AI-08**

### Boiler Inspection Certificate

Expiration Date <b>11/19/2026</b>	Inspection Date 11/19/2026	Next Watersides/Firesides 2026/2026	Next Strength Test	National Board # 261917
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar	Year Built 2021	
Building # Mechanical Room		Serial # 2237 130933471	Property # 3	Jurisdiction #
Pressure Allowed 80 psi	Capacity 285,000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar
Inspection Type(s) Performed		Fuel Type(s) Certified to Use		
<input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness		<input type="checkbox"/> Coal <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Heavy Fuel Oil <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Wood		
Commission # 13373	Inspector: Dale Brooks	Signature 		

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*

## Argent Inspections

### Form AI-08

### Boiler Inspection Certificate

Expiration Date <b>11/19/2026</b>	Inspection Date 11/19/2025	Next Watersides/Firesides 2027/2026	Next Strength Test	National Board # 280593
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar	Year Built 2021	
Building # Mechanical Room		Serial # 2226 1300077986	Property # 4	Jurisdiction #
Pressure Allowed 80 psi	Capacity 285,000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar
Inspection Type(s) Performed		Fuel Type(s) Certified to Use		
<input type="checkbox"/> Internal <input type="checkbox"/> Watersides <input type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input type="checkbox"/> Tightness		<input type="checkbox"/> Coal <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Heavy Fuel Oil <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Wood		
Commission # 13373	Inspector: Dale Brooks	 <i>Dale O. Brooks</i>		

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*

# Argent Inspections

## Form AI-08

## Boiler Inspection Certificate

Expiration Date <b>11/19/2026</b>	Inspection Date 11/19/2025	Next Watersides/Firesides 2028/2026	Next Strength Test	National Board # 72859
Customer 99th RSC R4C Z2 WV020 USARC Jane Lew		Manufacturer Lochinvar		Year Built 1997
Building # Mechanical Room		Serial # C873701	Property # 1	Jurisdiction #
Pressure Allowed 160 psi	Capacity 90,000 btuh	Safety Valves 1	Programmer Mfr Lochinvar	Burner Mfr Lochinvar
Inspection Type(s) Performed <input checked="" type="checkbox"/> Internal <input checked="" type="checkbox"/> Watersides <input checked="" type="checkbox"/> Firesides <input checked="" type="checkbox"/> External/Operational <input checked="" type="checkbox"/> Pressure Test <input type="checkbox"/> Strength <input checked="" type="checkbox"/> Tightness			Fuel Type(s) Certified to Use <input type="checkbox"/> Coal <input checked="" type="checkbox"/> Natural Gas <input type="checkbox"/> Light Fuel Oil <input type="checkbox"/> Wood <input type="checkbox"/> Heavy Fuel Oil	
Commission # 13373	Inspector: Dale Brooks	Signature 		

*POST THIS CERTIFICATE UNDER GLASS ON OR NEAR CERTIFIED BOILER*