


## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST PTAC

SITE AND BLDG #: <span style="color: blue;">WV022-01</span>	MECHANIC SIGNATURE: <span style="color: blue;">James R Groft</span>	DATE: <span style="color: blue;">03/20/2026</span>
LOCATION/RM #:                      WO# <span style="color: blue;">21394</span> ASSET # <span style="color: blue;">4687</span>	START TIME:	FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS <small>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</small>
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel, as needed.	X		
2	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean the filter with a vacuum or running water. Inspect filter quarterly, replace/clean as needed	X		
2	Remove the front grille and clean it with a dampened cloth.	X		
3	Inspect the control panel door and plug. Repair deficiencies.	X		
4	Check the caulking around the PTAC wall sleeve to make sure all air and water openings are properly sealed.	X		
5	Check that condensate drains properly. Remove any debris/blockages.	X		
6	Clean condenser coils with proper coil cleaner.	X		
7	Place drain pan cleaner tablet in the basepan to inhibit bacteria growth.	X		
8	Check clearance around the HVAC unit to ensure that the intake air and discharge air paths are not blocked or restricted	X		
9	Clean up work area.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials) per occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**