

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **OIL WATER SEPARATOR**

SITE AND BLDG #: W022 oms
LOCATION/RM #: OWS 18240 **WO#** 9237 **ASSET #** 9237

MECHANIC SIGNATURE:  **DATE:** 5-16-25
START TIME: 1200 **FINISH TIME:** 1500

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	OIL LAYER - If possible, measure the surface oil layer in the oil water separator and record depth.	✓		
2	SOLID ACCUMULATION - If possible, measure the solid accumulation in the bottom of the oil water separator and record.	✓		
3	Recommend whether oil water separator needs to be cleaned.	✓		cleaned 5-14-25

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

Additional Notes: