

REVIEWED

By Mike Merchan at 9:28 am, Mar 08, 2019

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

SITE AND BLDG #: WV024-01**MECHANIC
SIGNATURE:****DATE:** 3-4-19**LOCATION/RM #:****START TIME:**

12 PM

FINISH TIME:

2 PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV024-01	7661	4859		Amtrol	ST5	24113502	J-1502000-12 1-pc Expansion Tank	Mech Rm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	✓			
2	Test air pressure in tank. Ensure air pressure is at correct PSI. Correct as needed.		✓	<i>TANKS Need Replaced</i>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

Found two tanks and both tanks have busted bladders and need replaced!

Scheduling tank changing with personnel!

