

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: WV024-02

MECHANIC
SIGNATURE: *Mike B* DATE: 4-17-19

LOCATION/RM #:

START TIME: 8AM FINISH TIME: 12PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV024-02	8352	7435		<i>NA</i>			J-1502000-45 2-pc Double Light, Pole Mounted Aluminum LED	<i>Motor Pool</i>

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<i>✓</i>		
2	Schedule and coordinate work with operating personnel.	<i>✓</i>		
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<i>✓</i>		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.	<i>✓</i>		
2	Inspect visual condition of wiring. Look for evidence of overheating.	<i>✓</i>		
3	Check for proper light operation.	<i>✓</i>		
4	Test operation of automatic switches/ time clock/ photocells if applicable.		<i>✓</i>	<i>NA</i>
5	Inspect light pole and mounting devices for deficiencies.	<i>✓</i>		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	<i>✓</i>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**



Light Needs
to be turned to
Shine in
Motor Pool.