

CMI Management Inc.

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
PTAC**

SITE AND BLDG #: WV024

MECHANIC SIGNATURE: Brian M. Smart **DATE:** 3-24-2026

LOCATION/RM #: _____ **WO#** 21386 **ASSET #** 4651

START TIME: 800AM **FINISH TIME:** 330PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel, as needed.			
2	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean the filter with a vacuum or running water. Inspect filter quarterly, replace/clean as needed			This unit has been waiting replacement from Casto's for over a year.
2	Remove the front grille and clean it with a dampened cloth.			
3	Inspect the control panel door and plug. Repair deficiencies.			
4	Check the caulking around the PTAC wall sleeve to make sure all air and water openings are properly sealed.			
5	Check that condensate drains properly. Remove any debris/blockages.			
6	Clean condenser coils with proper coil cleaner.			
7	Place drain pan cleaner tablet in the basepan to inhibit bacteria growth.			
8	Check clearance around the HVAC unit to ensure that the intake air and discharge air paths are not blocked or restricted			
9	Clean up work area.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: