




PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: WV029-01MECHANIC
SIGNATURE:DATE: Aug 13, 2024LOCATION/RM #: WO# 16173

START TIME: _____ FINISH TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO			
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Check, clean, and/or replace filters as required.					
2	Initial and Date Filter (if disposable)					
3	Initial and Date Yellow Maintenance Tag (if applicable)					
ASSET #	SIZE	QTY				
	Record Size :					
3051	16x20x2	10				
3052	16x25x2	4				
	20x24x2	4				
						
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly					
	All other filters get replaced annually But inspected Quarterly					

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: