

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

UNIT HEATER, HOT WATER


SITE AND BLDG #: WV029-01

MECHANIC

SIGNATURE: James R Groft JrDATE: 07/30/2025LOCATION/RM #: _____ WO# 19453 ASSET # 9269

START TIME: _____

FINISH TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel.		X	Unit is already shut down during cooling season
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	X		
2	Clean the coils	X		
3	Comb the fins as needed.	X		
4	Clean all fans and motors.	X		
5	Check operation of controls and safeties.	X		
6	Lubricate as required.	X		
7	Check all motors, belts, pulleys, shafts, etc. for alignment.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: