

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

VAULT DOOR

**SITE AND BLDG #:** WV031-01  
**MECHANIC SIGNATURE:** Mike Merchant **DATE:** 31 JULY 01

LOCATION/RM #: \_\_\_\_\_

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV031-01	9781	7920					J-1502000-55 1-pc Arms Vault Rm 120	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			See con
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check alignment of dial ring with lock case; correct if necessary.			
2	Check mounting screws of dial ring and lock case; tighten them, using a thread locking compound.			
3	Look for corrosion or presence of any foreign matter that will in any manner affect the lock's proper operation.			
4	Look for any signs of malfunctioning or impending failure.			
5	Look for any signs of tampering, forced, or covert entry; report this to the local Security and Law Enforcement Office.			
6	Check Alignment of door with frame			
7	Check for difficulty in opening, closing or locking the door.			

8

Replace all defective hardware

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker Additional Notes: