

REVIEWED

By Michael Merchan at 7:10 am, Feb 12, 2019

*A CM ticket will be needed to replace the sump pump

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**ICE MAKER****MECHANIC****SIGNATURE:****DATE:****START TIME:** 7:30**FINISH TIME:** 3:30**SITE AND BLDG #:** WV031-01**LOCATION/RM #:** Assembly Hall

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV031-01	7382	6830		Manitowoc	QY0134A	2056576	J-1502000-23 1-pc Ice Maker, Hotel/Motel Machine Filter Feb	Assembly Hall

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Review manufacturer's instructions.	/		
2	De-energize, lock out, and tag electrical circuits.	/		
3	If appliance is disposed, follow regulations concerning removal of refrigerants and disposal of the appliance.	/		
4	If materials containing refrigerants are discarded, comply with EPA regulations as applicable.	/		
5	Only approved cleaning chemicals shall be used.	/		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check with operating or area personnel for any deficiencies; verify cleaning program.	/		
2	Visually check for refrigerant, oil, and water leaks.	/		
3	Inspect ice condition/size.	/		
4	As needed, drain and clean unit with proper ice machine cleaning solution.	/		

5	Check date on water filter, replace as needed. Water filters should be changed annually at a minimum.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<i>n/n</i>
6	Check and tighten any loose screw-type electrical connections.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
7	Check all controls; adjust if necessary.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
8	Examine water connection; open and close water valve; test ice dispensing valve and (door) metering adjustment.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
9	Check and clear ice machine draining system (drain vent, strainer, trap).	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<i>Drainage Pump Inoperable / Needs Replaced</i>
10	Examine condition of bin doors-closure, hinges, gaskets, handles and ease of slide; lubricate as required. Check storage bin condition.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
11	Clean motor, compressor, and condenser coil.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

