

REVIEWED

By Michael Merchan at 7:12 am, Feb 12, 2019

TIDEWATER-ELEC-SLP-01

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **PHOTOCELL CONTACTS**

MECHANIC

SIGNATURE:

Patrick Davis

DATE:

11 February '19

ACTIVITY AND BLDG #: WV031-02

LOCATION:

LOT

START TIME:

7:30

FINISH TIME:

3:30

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV031-02	7330	7460		N/A	N/A	N/A	J-1502000-45 4-pc Motor Vehicle Area Light Wood LED Photocell Contacts	LOT

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer’s recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Review manufacturer's instructions.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean solar panels thoroughly to ensure surface is free of dirt, dust, bug residue, etc.	✓		
2	Inspect panels to determine if any panels exhibit cracks, breaks, or defects that would be cause for concern, repair or replace as needed.	✓		
3	Inspect wiring for damage, fraying, discoloration, etc. Repaire or replace as needed.	✓		
4	Ensure controller is operating properly and free from damage. Report any deficiencies	✓		

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence.

Checklist compiled in accordance with:

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at ([Provide Link to OEM Manual/Asset Library](#))

Additional Notes:

