

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR CONDENSING UNIT

SITE AND BLDG #: WV031-02

MECHANIC
SIGNATURE:

Dusty Bird

DATE: 5-22-19

START TIME:

7:30 AM

FINISH TIME:

9 AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV031-02	8727	3240	PM-SA-3240				J-1502000-04 1-pc Condensing Unit	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓			
2	Schedule outage of unit with personnel in area the unit serves.	✓			
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓			
4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	✓			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Remove debris from air screen and clean underneath unit.	✓			
2	Wash coil with coil cleaning solution - Rinse Thoroughly	✓			
3	Straighten fin tubes with fin comb, as needed.		✓	N/A	
4	Check electrical connections for tightness.	✓			
5	Check mounting base for tightness.	✓			
6	Inspect fans for bent blades, unbalance, excessive noise, and vibrations.	✓			
7	Inspect all piping for leaks and tighten loose connections.	✓			

8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	✓		
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.	✓		
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓		
11	Clean up work area.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: HVAC Technician **Additional Notes:**

