

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **VEHICLE EXHAUST REMOVAL**

**MECHANIC
SIGNATURE:**



DATE: 6-7-11

SITE AND BLDG #: WV031-02

LOCATION/RM #:

START TIME: 11:00

FINISH TIME: 12:00

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV031-02	9346	8067					J-1502000-57 2-pc Overhead Vehicle Exhaust System	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer’s recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	X		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Start and stop fan with local switch	X		
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	X		
3	Inspect, adjust belts and pulleys. Replace belt as needed.	X		
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	X		
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	X		
6	Clean fan as needed.	X		
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	X		

8	Repair as needed			
---	------------------	--	--	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

