



OneCIS Insurance Company

95 Oakwood Rd
Lake Zurich, IL 60047
(855) 593-5115
www.us.bureauveritas.com

9/4/2019

44110-007211.00

International Support Group
1370 North State St
New Martinsville, WV 26155

RE: Jurisdictional Inspection:
International Support Group
1370 North State St
New Martinsville, WV 26155

Thank you for the consideration I received during my visit on August 21, 2019 at your facility listed above. The purpose of the visit was to perform the jurisdictional inspections of the objects listed below to determine compliance with ASME/National Board standards and regulations. I was accompanied by SSGT John Thomas during my visit.

The inspections were performed on behalf of International Support Group (US Army Reserve Offices).

The following objects were inspected at the time of the visit:

Year Built	Type of object	Jurisdictional Number	NB Number	Recommendation(s)
	Other	WV031BLR1	217926	None
	Other	WV031BLR2	217626	None
	Other	WV031BLR3	217925	None

The following observations were noted during the inspection of this equipment:

Each Boiler was inspected externally and found free of defect or damage. Required safety devices are installed and appear to be in good working order. Pressure relief devices were tested and found in satisfactory condition.

As a result of these inspections 0 new recommendations were suggested.

Based upon this visit and the results of the National Board Inspection Code (**NBIC**) inspection requirements, OneCIS Operating Certificates for each boiler are being created and forwarded to the client.

The next inspection is tentatively scheduled to be completed by 08/21/2020.

Please contact me by phone at 571-373-0998 or by e-mail at william.johnson@onecis.com if there are any questions or if I may be of further assistance.

Sincerely,

William Garth Johnson

William Garth Johnson
B&M Jurisdictional Specialist

DISTRIBUTION

Cc:

International Support Group
Jamie Merchant
9050 Pines Blvd Ste 150
Pembroke Pines, FL 33024-6400
jmerchant@internationalsupportgroup.com