



**BUREAU
VERITAS**

CERTIFICATE OF BOILER OR PRESSURE VESSEL INSPECTION

This is to certify that the herein-described:

☒Boiler ☐Pressure Vessel

Inspected by: **Bureau Veritas: OneCIS – An accredited Authorized Inspection Agency (AIA)**

May be operated at a pressure not to exceed 160 pounds per square inch.

NAME OF USER:

WV-031, US Army Reserve Center

STREET ADDRESS

1370 North State St

CITY

New Martinsville

COUNTY

STATE

WV

ZIP CODE

26155

NAME OF OWNER (if different from above)

MAIL ADDRESS (if different from above)

CITY

STATE

ZIP CODE

TYPE OF BOILER/PRESSURE VESSEL

HWH Boiler

LOCATION

Boiler Room

BUILT BY

Laars

NATIONAL BOARD OF OTHER I.D. NO.

NB 217926, asset #6636blr

YEAR BUILT

Est. 1997

DATE OF INSPECTION

8/21/2019

INSPECTION TYPE

external

INSPECTOR SIGNATURE & National Board Comm. #

Garth Johnson, NB Comm. #12820

Please direct all **Inspection Requests** and **Inquiries** to:
1-855-593-5115

POST THIS CERTIFICATION IN A CONSPICUOUS
PLACE NEAR THE BOILER/VESSEL.