

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**MOTION SENSORS**

**SITE AND BLDG #:**WV035-01

**MECHANIC**

**SIGNATURE:** Mike Mechan **DATE:** 23 Jul 19

**LOCATION/RM #:**

**START TIME:** 1:30 PM **FINISH TIME:** 2:15 PM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Physical Asset Location
WV035-01	9705	6498					J-1502000-18 3-pc Motion Sensor	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	NOTES/ ACTIONS (If Task Complete is checked no. provide explanation)
		YES	NO		
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>			
2	Schedule and coordinate work with operating personnel.	<input checked="" type="checkbox"/>			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>			Completed. See COW
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check for proper functioning.	<input checked="" type="checkbox"/>			
2	Inspect visual condition of motion lens.	<input checked="" type="checkbox"/>			
3	Check for proper light operation.	<input checked="" type="checkbox"/>			
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	<input checked="" type="checkbox"/>			

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found

exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: