

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER

SITE AND BLDG #: WV035-01

MECHANIC
SIGNATURE:

DATE: 6-27-15

LOCATION/RM #:

START TIME: 9:45

FINISH TIME: 11:00

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV035-01	9391	4077					J-1502000-08 1-pc Unit Heater	
WV035-01	9391	4078					J-1502000-08 1-pc Unit Heater	
WV035-01	9391	4549					J-1502000-08 3-pc Unit Heater	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule shutdown with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.	✓		
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	✓		
3	Clean the coil with vacuum cleaner.	✓		

4	Comb the fins as needed.	<input checked="" type="checkbox"/>		
5	Clean all fans and motors.	<input checked="" type="checkbox"/>		
6	Check operation of controls and safeties.	<input checked="" type="checkbox"/>		
7	Lubricate as required.	<input checked="" type="checkbox"/>		
8	Check all motors, belts, pulleys, shafts, etc. for alignment.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

