

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**UNIT HEATER, HOT WATER**

**SITE AND BLDG #:** WV035-02

**MECHANIC  
SIGNATURE:** 

**DATE:** 6-20-13

**LOCATION/RM #:**

**START TIME:** 10:45 AM **FINISH TIME:** 10:45 AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV035-02	9463	4456					J-1502000-08 1-pc Unit Heater, Spark Resistant	
WV035-02	9463	4457					J-1502000-08 1-pc Unit Heater, Suspended, HotWater, Spark Resistant	
WV035-02	9463	4627					J-1502000-08 9-pc Unit Heater, Suspended, Hot Water	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
SPECIAL INSTRUCTIONS					
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	X			
2	Schedule shutdown with operating personnel.		X	Units were not in use	
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check valve for full stroke operation in both directions, if applicable.	X			
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	X			

3	Clean the coil with vacuum cleaner.		X	Not needed
4	Comb the fins as needed.		X	Not needed
5	Clean all fans and motors.		X	Clean
6	Check operation of controls and safeties.	X		
7	Lubricate as required.		X	Not needed
8	Check all motors, belts, pulleys, shafts, etc. for alignment.		X	Running properly

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**



All 3 units were  
Powered up and  
checked to make  
sure they were running  
properly.