

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**UNIT HEATER, HOT WATER**

**SITE AND BLDG #:** WV035

**MECHANIC  
SIGNATURE:**

**DATE:** 7-18-2024

**LOCATION/RM #:** WO#16055 **ASSET #**

**START TIME:** 730

**FINISH TIME:** 300PM

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS</b> (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		<b>YES</b>	<b>NO</b>	
<b>SPECIAL INSTRUCTIONS</b>				
1	Schedule shutdown with operating personnel.	<input checked="" type="radio"/>	<input type="radio"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="radio"/>	<input type="radio"/>	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	<input checked="" type="radio"/>	<input type="radio"/>	
2	Clean the coils	<input checked="" type="radio"/>	<input type="radio"/>	
3	Comb the fins as needed.	<input checked="" type="radio"/>	<input type="radio"/>	
4	Clean all fans and motors.	<input checked="" type="radio"/>	<input type="radio"/>	
5	Check operation of controls and safeties.	<input checked="" type="radio"/>	<input type="radio"/>	
6	Lubricate as required.	<input checked="" type="radio"/>	<input type="radio"/>	
7	Check all motors, belts, pulleys, shafts, etc. for alignment.	<input checked="" type="radio"/>	<input type="radio"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:** Assets -4456,4457,4627