

CMI Management Inc.

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
CHEMICAL BYPASS/POT FEEDER**

**SITE AND BLDG #:** WV035

**MECHANIC SIGNATURE:** *Brian M. Smart* **DATE:** 12-15-2025

**LOCATION/RM #:** WO# 20701 ASSET # 9292

**START TIME:** 730 **FINISH TIME:** 330

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS <small>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</small>
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check physical condition of feeder. Clean and/or repair as needed.	●		
2	Check valves for proper operation. Ensure no leaks are present and repair as needed.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**

