

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV035 Date of Visit: 12-16-2024

Contractor Personnel on Site:

1. Brian Mcderment 2. December Pm

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

WO-17113 9309,9313 WO-17175 G070 WO-17186 9303  
1. ~~WO-17191 4635,4636,4637~~ WO-17271 9292 WO-17272-  
9295,9296,9297 WO-17273 9300,9302 WO-17337 9301,9308  
Service Calls - Service Call Number and Description  
WO-17176 G071 WO-17205 4682 WO-17177 G072

1. CSS# \_\_\_\_\_  
2. CSS# \_\_\_\_\_  
3. CSS# \_\_\_\_\_

---

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Brian Mcderment Date: 12-16-2024

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, I certify that the above-named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed. This is **NOT** a Certification that the Work was performed correctly – The COW simply verifies that that someone representing the Contractor was onsite and accomplished something

Print Name/Rank: \_\_\_\_\_ Date: 12-16-2024

Signed: 

E-Mail: \_\_\_\_\_

7 out of 9 of these suspended hot water heaters in the motor pool at wv 035 have have motors with seized bearings and the motors will need to be replaced before the heaters can function. Sending quote info to Reg.  
NOTE ; These heaters where actually on July Pm Schedule but I could not access them then because i needed a lift.

