


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GREASE TRAP

SITE AND BLDG #: **WV 041-01**
LOCATION/RM #: **Kitchen** WO# **10822** ASSET # **7487**

MECHANIC SIGNATURE: 
DATE: **9/20/19**

START TIME: **800** FINISH TIME: **810**

CHECK ITEM	DESCRIPTION	TASIS COMPLIANCE		NOTES/EXCLUSIONS
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
3	Insure proper grease disposal.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Do not use enzymes, acids, caustics, solvents or emulsifying products when cleaning or maintaining the grease traps.	/		
2	Remove lid. If the trap is equipped with removable baffles, remove them.	/		
3	Make sure the flow restrictor on the inflow pipe is present.	/		
4	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.	/		
5	Replace lid and baffles.	/		
6	Return (or fill) water to grease trap.	/		
7	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes:

BK